

State of New York Department of Health
Saranac Lake District Office
41 St. Bernard Street
Saranac Lake, NY 12983-1834
(518) 891-1800
saranaclake@health.ny.gov

Water System Field Compliance Inspection Summary Report

Operation: Ticonderoga WD (ID: 360024)
Facility Name: TICONDEROGA WD
Facility Code: 1500293 Facility Email: tiwater@townofticonderoga.org
Facility Address: Route 74, Ticonderoga, NY 12883
NYS Public Water Supply (PWS) ID: NY1500293

To the Attention of:

Derrick Fleury
Town of Ticonderoga
P.o. Box 471
Ticonderoga, NY 12883
Email: tiwater@townofticonderoga.org

Sanitary Survey

Date: September 11, 2025 08:30 AM
Inspector: Marlene Martin (marlene.martin@health.ny.gov)
Responsible Person: Derrick Fleury

Summary

Number of Critical Violations Found: 1
Number of Other Violations Found: 0
Number of Deficiencies Found: 0

Reinspection is not Required

Each item found in violation is reported below along with the code requirement.

CRITICAL VIOLATIONS FOUND

5-1.30(B): FILTRATION OF A SURFACE SOURCE OR GROUNDWATER INFLUENCED BY SURFACE WATER

Corrected at time of inspection? No

Inspector Findings: ****THIS IS A REPEAT VIOLATION FROM AUGUST 2, 2011**** The Gooseneck Pond water source does not receive filtration, is only chlorinated, and avoidance criteria are not met. The Town currently has an Administrative Tribunal enforcement action from the DOH and an Administrative Order from the EPA to address this issue. The Town continues to work towards resolving this violation.

NO NON-CRITICAL VIOLATIONS REPORTED

NO DEFICIENCIES REPORTED

Water System Information

Source Type: Surface, Ground,

Type of Disinfection: Chlorine (Cl),

Disinfection Waiver Issued? No

4-Log Treatment Installed? No

Coliform Surveillance Sample Collected? No


Chlorine Residual Reading(s):

1) CI Residual: 1.1 Time: 8:35 AM Location: gooseneck wtp

2) CI Residual: 1.3 Time: 10:40 P Location: Lake George wtp

Water System Notes:

Comments: No new violations or deficiencies were noted during the inspection. The operator continues to provide exceptional due care and diligence in the operation and maintenance of the water system.



Inspector: Marlene Martin (marlene.martin@health.ny.gov)